



[ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ]

<b>Office of the Assistant Executive Engineer,</b> Public Works Department Division, Chintamani – 563 125	ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್ ರವರ ಕಛೇರಿ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ ಉಪ ವಿಭಾಗ, ಚಿಂತಾಮಣಿ - 563 125
<b>E-mail: aecntkpwd@gmail.com</b> Phone/Fax No: ದೂರವಾಣಿ/ಫ್ಯಾಕ್ಸ್ ಸಂಖ್ಯೆ: 08154-295058	

ಸಂಖ್ಯೆ: ಸ.ಕಾ.ಇಂ./ಲೋ.ಇ/ಉಪ/ಚಿಂತಾಮಣಿ/ಸಇಂ/ಕಟ್ಟಡ ದೃಢತಾ ಪತ್ರ/2024-25/ 272 ದಿನಾಂಕ: 23-08-2024  
ರವರಿಗೆ,

**Principal,**  
Jain Public School  
ಕಾವಲಗಾನಹಳ್ಳಿ

ಚಿಂತಾಮಣಿ ತಾಲ್ಲೂಕು, ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ

ವಿಷಯ:-	ಶಾಲಾ ಕಟ್ಟಡದ ದೃಢತೆಯ ನಿರಾಕ್ಷೇಪಣಾ ಪ್ರಮಾಣ ಪತ್ರ (Structural Stability Certificate) ನೀಡುವ ಕುರಿತು.
ಉಲ್ಲೇಖ:-	1. ಸರ್ಕಾರದ ಸುತ್ತೋಲೆ ಸಂ:ಲೋ.ಇ 59 ಬಿಇಡಿ 2019 ದಿನಾಂಕ: 06-05-2022.
	2. ತಮ್ಮ ಮನವಿ ಪತ್ರದ ದಿನಾಂಕ: 07-08-2024

\*\*\*\*\*

ಮೇಲಿನ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಪಟ್ಟಂತೆ ಉಲ್ಲೇಖ (2) ರ ಪತ್ರದಲ್ಲಿ ಕೋರಿರುವಂತೆ ಶಾಲಾ ಕಟ್ಟಡವನ್ನು & ಈ ಕಛೇರಿಗೆ ಸಲ್ಲಿಸಿರುವ ದಾಖಲೆಗಳನ್ನು ಪರಿಶೀಲಿಸಿ, ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಿಸಿ ಉಲ್ಲೇಖ (1) ರಲ್ಲಿ ಹೊರಡಿಸಿರುವ ಸರ್ಕಾರಿ ಸುತ್ತೋಲೆಯಂತೆ ಶಾಲಾ ಕಟ್ಟಡದ ದೃಢತೆಯ ನಿರಾಕ್ಷೇಪಣಾ ಪ್ರಮಾಣ ಪತ್ರ (Structural Stability Certificate) ಈ ಕೆಳಕಂಡಂತೆ ನೀಡಿದೆ.

1.	ಶಾಲೆಯ ಹೆಸರು & ವಿಳಾಸ	Jain Public School ಕಾವಲಗಾನಹಳ್ಳಿ, ಚಿಂತಾಮಣಿ ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ
2.	ನಿರ್ಮಾಣ ವರ್ಷ	2019-20
3.	ಪರಿವೀಕ್ಷಣಾ ದಿನಾಂಕ:	22-08-2024
4.	ಕಟ್ಟಡದ ಸ್ವರೂಪ	Type of Structure Walls Flooring Roof Joineries RCC Structure (G+2) BBM Vitrified and Granite Tiles RCC roofslab Wooden Doors & windows
5.	Type of NDT Conducted & results	Rebound hammer Test & Ultrasonic Pulse Velocity Test conducted by M/S Karnataka Test House Pvt., Ltd., Triveni Road, Yeshwanthpur Bangalore, NABL Accredited Laboratory as per ISO/IEC 17025 & Result found satisfactory.
6.	ಮೇಲ್ನೋಟಕ್ಕೆ ಕಟ್ಟಡದ ಸ್ಥಿತಿ	Ramps not provided and dampness and cracks in walls observed.
7.	ಪ್ರಮಾಣ ಪತ್ರ ಶುಲ್ಕ	ರೂ. 1000.00, ಚಲನ್ ನಂ.ಸಿಆರ್ 0824005900372742 ದಿನಾಂಕ: 22-08-2024
8.	ಕಟ್ಟಡದ ದೃಢತೆ	ಕಟ್ಟಡವು ಮೇಲ್ನೋಟಕ್ಕೆ ಸದೃಢವಾಗಿದ್ದು, ಗೋಡೆಯಲ್ಲಿರುವ ಅತಿಸಣ್ಣ ಬಿರಕು & ತೇವಾಂಶವನ್ನು ಸರಿಪಡಿಸುವ ಷರತ್ತಿಗೊಳಪಟ್ಟಿರುತ್ತದೆ. ಕಟ್ಟಡವು ಶಾಲೆ ನಡೆಸಲು ಸೂಕ್ತವಾಗಿರುತ್ತದೆ.

ಷರತ್ತುಗಳು:-

1. ಕಟ್ಟಡವನ್ನು ಕಾಲ ಕಾಲಕ್ಕೆ ಸರಿಯಾದ ರೀತಿಯಲ್ಲಿ ನಿರ್ವಹಣೆ ಮಾಡುವುದು
2. ಶೌಚಾಲಯವನ್ನು ಸ್ವಚ್ಛವಾಗಿರುವುದು
3. ಶಾಲಾ ಆವರಣದಲ್ಲಿ ನೀರಿನ ವ್ಯವಸ್ಥೆಯನ್ನು ಸೂಕ್ತ ರೀತಿಯಲ್ಲಿ ನಿರ್ವಹಿಸುವುದು
4. ಶಾಲಾ ಆವರಣವನ್ನು ಸ್ವಚ್ಛವಾಗಿರಿಸಿಕೊಳ್ಳುವುದು
5. ಕಟ್ಟಡವನ್ನು ವಾರ್ಷಿಕವಾಗಿ ಸುಣ್ಣ ಬಣ್ಣ ಬಳಿದು ನಿರ್ವಹಿಸುವುದು
6. ಕಟ್ಟಡದ ಮತ್ತು ಆವರಣದ ಸುರಕ್ಷತೆಯನ್ನು ಸಂರಕ್ಷಿಸುವುದು.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್,  
ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಉಪ ವಿಭಾಗ,  
ಚಿಂತಾಮಣಿ

Format for Application to be submitted by the Educational organizations.

1	Name and address of the building	Jain public school. Karalagana halli, Chintamani
2	Number of stories approved in the sanction building Plan	Ground + 2 Floors
3	Year of construction	2019-20
4	Submission of Following documents are not mandatory for the building already constructed and working. But mandatory for new buildings	
a)	Approved building plan from the competent authority	Enclosed/Not enclosed
b)	Completion certificate duly signed by the Supervision Engineer who is in charge of the building	Enclosed/Not enclosed

Date: 23/08/2024

Place: Chintamani

  
**PRINCIPAL**  
**JAIN PUBLIC SCHOOL**  
**CHINTAMANI**

(Seal and Signature of the Organization)

Remarks of the inspecting Authority

ಕಟ್ಟಡವು ಮೇಲ್ಕೆಲಸಕ್ಕೆ ಸಿದ್ಧವಾಗಿದ್ದು, ಸೀಲಂಟ್‌ನಲ್ಲಿ  
 ಅತಿಸಣ್ಣು ಋರುಳು & ತೇವಾಂಶವನ್ನು ತಡೆಗಡಿಸುವ  
 ಪೈಪ್‌ಲೈನ್‌ಗಳ ಸಜ್ಜೆ ಕಂಡು ಬಂದಿದೆ.

  
 (Seal and Signature of the Authority)  
 Assistant Executive Engineer,  
 P.W.D. Sub-Division  
 CHINTAMANI